

# **Validation Guide**

# PES Filter Cartridges 0.2µm



# Contents

<b>1. Introduction</b>
1.1 Product Description1
1.2 Materials of Construction1
1.3 Ordering Information2
<b>2. Validation Item</b>
<b>3. Test Methods and Results</b> 4
3.1 Correlation of non-destructive integrity testing to liquid bacterial challenge with <i>Brevundimonas diminuta</i> (ATCC 19146) for sterilising grade filters
3.2 Integrity Test Standard(20℃)7
3.3 Flow Characteristic(20°C)7
3.4 Maximum Operating Conditions8
3.5 Steam Sterilization (Thermal Stability)8
3.6 Cleanness10
3.6.1 Gravimetric Extractable10
3.6.2 Fiber Releasing10
3.7 Biological11
3.7.1 Biological Safety11
3.7.2 Bacterial Endotoxin: LAL Test13
3.8 Chemical Compatibility13



# **1.Introduction**

#### **1.1 Product Description**

PES 0.2µm filter cartridges are sterilize grade cartridge filters manufactured from asymmetric polyethersulfone membrane and polypropylene hardware providing high flow rates and throughputs, low extractable, broad chemical compatibility. PES 0.2µm cartridge filters are 100% integrity tested during manufacturing to assure sterilizing-grade performance.

The PES 0.2µm filter cartridges are designed for removal of particles and the sterile filtration of aqueous solutions.

The PES 0.2µm filter cartridges are designed, developed and manufactured in accordance with an ISO 9001 certified quality management system. These filters are manufactured in a controlled environment that meets the air quality standards of an ISO class 8 room with respect to viable and nonviable particulate and positive pressure.

#### **1.2 Materials of Construction**

1.2.1Component materials used in this product meets the FDA Indirect Food Additive requirements cited in 21 CFR 177-182.

Items	Material
Filter media	asymmetric polyethersulfone membrane
Support	polypropylene
Cage	polypropylene
Core	polypropylene
End Caps	polypropylene with embedded stainless steel ring
0-ring	silicone

1.2.2Component materials used in this product meets the regulation(EC)No.1935/2004.

Items	Material
Filter media	asymmetric polyethersulfone membrane
Support	polypropylene
Cage	polypropylene
Core	polypropylene
End Caps	polypropylene



# 1.3 Ordering Information

Application	Туре	Material	Micron	Length	Adaptor	Sealing R
D- Dorsan Biopharma Food&Beverage	<b>PES</b> Pleated Filter	PES	0.2µm	5″ 10″ 20″ 30″ 40″	E2-222/Flat with SS insert E3-222/Fin with SS insert E7-226/Fin with SS insert E6-226/Flat with SS insert	S S-Silicone E-EPDM N-NBR V-Viton F-PTFE F-Encapsuled Viton K-Encapsuled Silicone

# The Catalogue Number is shown as below:

Adaptor No.	Description	Тор	Bottom
<b>BLANK SPACE</b>	DOE		
E7	226/Fin with SS insert		
E6	226/Flat with SS insert		
E2	222/Flat with SS insert		0
E3	222/Fin with SS insert		



# 2. Validation Item

3.1 BCT (ASTM F838-20)		3.2 Integrity Test
Flow Rate	3.3 Flow Characteristic	
Durability	3.4 Maximum Operating Conditions	3.5 Steam Sterilization
Cleanness	3.6.1 Gravimetric Extractables	3.6.2 Non-Fiber Releasing
Biological	3.7.1 Biological Safety	3.7.2 Bacterial Endotoxin
Chemical	3.8 Chemical Compatibility	



# **3.Test Methods and Results**

# **3.1Correlation of non-destructive integrity testing to liquid bacterial challenge with** *Brevundimonas diminuta*(ATCC 19146) for sterilize grade filters

# 3.1.1 Introduction

The FDA guidelines on Sterile Products Produced by Aseptic Processing (2004) state, "A sterilizing filter is one which, when challenged with the micro-organism *Brevundimonas diminuta* (*B. diminuta*), at a minimum concentration of 10<sup>7</sup> organisms per cm<sup>2</sup> of filter surface, will produce a sterile effluent".

In order to meet the requirements of this guideline, liquid challenge tests using *Brevundimonas diminuta* (ATCC 19146) were performed with PES filter cartridges using a minimum of 1x10<sup>7</sup> colony forming units (CFU)/cm<sup>2</sup> of effective filtration area.

The correlation between microbial retention and a non-destructive integrity test is also an important aspect of the validation of sterilizing grade filters. The FDA guideline further states, "After a filtration process is properly validated for a given product, process and filter, it is important to assure that identical filter replacements (membrane or cartridge) used in production runs will perform in the same manner. One way of achieving this is to correlate filter performance data with filter integrity testing data". The integrity tests used during this validation study were the Forward Flow and Bubble Point tests.

#### The Forward Flow Integrity Test

In the Forward Flow test, a filter is wetted with a suitable test liquid and a pre-determined gas pressure is applied to the upstream side of the filter assembly. After a stabilization period, the gas flow through the wetted membrane can be measured manually on the downstream side or on the upstream side, using sensitive flow measurement equipment such as the integrity test devices.

# The Bubble Point Integrity Test

In the Bubble Point test, a filter is wetted with a suitable test liquid. After a stabilization period, increasing the gas pressure to the upstream side of the filter assembly, using sensitive flow measurement equipment such as the integrity test devices to test the change point of the gas flow rate.



#### 3.1.2 Summary of Methods



PES 0.2µm filter with different batch lots were subjected to microbial challenge tests using an aqueous suspension of *Brevundimonas diminuta* (ATCC 19146). Prior to the challenge tests the filters were installed in an appropriate housing, flushed with DI water at a flow rate of 4 L/min for 15~20 minutes, and then autoclaved at 121 °C for 30 minutes. The filter assembly was then aseptically connected to a pre-sterilized challenge apparatus.

A Forward Flow integrity test was then performed using an integrity test instrument with an air test pressure of 2.75bar (39.8 psi).

An aqueous suspension of *Brevundimonas diminuta* was passed through the filter to achieve a challenge level of  $> 1 \times 10^7$  colony forming units (CFU) per cm<sup>2</sup> of effective filtration area.

During the challenge test, the entire filter effluent was passed through a 0.2 µm-rated analysis disc on the downstream side of the test filter assembly. The filter disc was incubated on TSA and following incubation, the disc was examined to determine if any colonies had grown, indicating whether or not bacteria had passed through the test filter during the challenge.



#### 3.1.3 Test Results

Table listed below indicates PES 0.2µ m that are forward flow tested before and after bacterial challenge. The bacterial challenge was conducted using ASTM F838-20 to provide the necessary correlation between a bacterial challenge and a non-destructive integrity test. Filter type: PES 10", 0.2µ m

Challenge organism: Brevundimonas Diminuta (ATCC 19146)

Filter Serial	Forward Flow	Challenging	Sterile	LRV/
Number	mL/min	bacteria(CFU/10inch)	Effluent	cm <sup>2</sup>
401190611009	12.8	1.15*10 <sup>11</sup>	Yes	7.28
401190611008	13.4	1.19*10 <sup>11</sup>	Yes	7.29
401190611003	14.7	2.61*10 <sup>11</sup>	Yes	7.63
311100811028	15.2	2.67*10 <sup>11</sup>	Yes	7.64
401190611007	15.7	1.7*10 <sup>11</sup>	Yes	7.45
401190611011	16.1	1.81*10 <sup>11</sup>	Yes	7.47
311100811028	16.3	2.54*10 <sup>11</sup>	Yes	7.62
311170311010	16.4	2.61*10 <sup>11</sup>	Yes	7.63
401190611032	17.1	3.21*10 <sup>11</sup>	Yes	7.72
401190611030	17.2	2.89*10 <sup>11</sup>	Yes	7.68
311100811008	17.4	1.98*10 <sup>11</sup>	Yes	7.51
311170311006	17.6	2.15*10 <sup>11</sup>	Yes	7.55
311170311003	17.7	1.68*10 <sup>11</sup>	Yes	7.44
311100811015	17.8	2.24*10 <sup>11</sup>	Yes	7.57
401190611002	17.9	2.16*10 <sup>11</sup>	Yes	7.55
401190611006	18.1	1.68*10 <sup>11</sup>	Yes	7.44
311100811016	18.2	1.71*10 <sup>11</sup>	Yes	7.46
311100811012	18.3	2.18*10 <sup>11</sup>	Yes	7.55
401190611024	18.4	2.24*10 <sup>11</sup>	Yes	7.57
401190611010	18.5	3.05*10 <sup>11</sup>	Yes	7.7
311100811023	18.6	2.61*10 <sup>11</sup>	Yes	7.63
311170311015	18.8	1.98*10 <sup>11</sup>	Yes	7.51
401190611015	19.1	1.23*10 <sup>11</sup>	Yes	7.31
401190611016	20.7	1.08*10 <sup>11</sup>	Yes	7.25
311100811007	22.5	1.35*10 <sup>11</sup>	Yes	7.35
311170311005	24.8	1.06*10 <sup>11</sup>	Yes	7.24
311170311017	25.9	1.23*10 <sup>11</sup>	Yes	7.31
401190611001	26.7	3.05 <sup>*</sup> 10 <sup>11</sup>	No	<7
311100811022	27.9	2.36*10 <sup>11</sup>	No	<7
311100811020	29.6	1.98 <sup>*</sup> 10 <sup>11</sup>	No	<7

#### **3.1.4 Conclusions**

A Typical PES 0.2µ m filters from production, 27pcs were found to pass the



forward flow integrity test. The table also indicates that a PES 0.2 $\mu$  m filter with Forward Flow  $\leq$ 26.7 mL/min/10"@ 2.75bar at 20°C has sterile filtration efficiency when challenged with > 1 x 10<sup>7</sup> CFU per cm<sup>2</sup> of filtration area using *Brevundimonas diminuta*.

Analysis in base of results of forward flow, tested filter  $\leq 25$ mL/min gave sterile effluent when challenged with LRV>7 of *B.diminuta*.

## 3.2Integrity Test Standard(20 $\pm$ 5 $^{\circ}$ C)

In base of test results of validation test, forward flow is approved as suitable test methods for PES 0.2 $\mu$  m filter cartridges. We also test the bubble point before and after bacterial challenge. The PES 0.2 $\mu$ m filter with bubble point  $\geq$ 3.3bar at 20 $^{\circ}$ C has sterile filtration efficiency.

The Integrity test value standard is as below:

Wetting Liquid	DI Water			
Temperature	20±5°C			
Test Gas	Air			
	Forward Flow:	≤25mL/min@2.75bar		
Allowable integrity value limit	Bubble Point:	≥3.3bar		

#### 3.3 Flow Characteristic(20 $\pm$ 5 $^{\circ}$ C)

#### 3.3.1 Summary of Methods

Typical PES filter cartridge from production were used for the tests. The filters were flushed with DI water@2.0bar for15-20mins. Then passed forward flow in base of 2.75bar air test pressure.

Standard production PES 0.2µm filter cartridge (10", EFA 0.6m<sup>2</sup>) were installed with flow rate test system device, which adjust the flow rate and pressure drop by auto-valve. Then take the continuous records with flow rate, upstream & downstream pressure value, temperature etc.

#### 3.3.2 Test Results

Here is the flow chart of filter cartridge





#### **3.3.3** Conclusions

These data can be used to assist users in sizing filter systems.

# **3.4 Maximum Operating Conditions**

#### 3.4.1Summary of Methods

Typical PES0.2µm filter cartridge from production were used for the tests. The filters were flushed with DI water@2.0bar for 15~20mins. Then passed forward flow in base of 2.75bar air test pressure.

Standard production PES 0.2µm filter cartridge(10", EFA 0.6m<sup>2</sup>) were installed with pressure drop test system device, which adjust the upstream and downstream pressure by auto-valve.

Use ISO Standard powers to increase the pressure drop till 5.0bar ,temperature  $25^{\circ}$ C and keep the pressure for 30mins, total 4 cycles.

Use Standard test dust to increase the pressure drop till 2.0bar,temperature 80  $^{\circ}$ C and keep the pressure for 30mins, total 3 cycles. Then test the integrity.

	Integrity Test(Befo pressure test)	ore the	Integrity Test(After the pressure test)		
Filter Serial Number	Forward Flow(mL/min@2.75bar)	Bubble Point(bar)	Forward Flow(mL/min@2.75bar)	Bubble Point(bar)	
401190611005	17, 5	3, 512	17, 2	3, 562	
401190611012	16. 4	3. 589	16, 2	3, 601	
312171511019	15. 6	3. 619	15. 6	3.699	
312150611020	15. 4	3. 465	15. 5	3, 491	
312150611022	16.8	3 517	16 7	3 528	

# 3.4.2 Test Results

The Integrity test value standard is forward flow≤25mL/min@2.75bar,bubble point ≥3.3bar,test temperature 20±5°C.

#### **3.4.3** Conclusions

Here is the Max. pressure drop and temperature of filter cartridge

Maximum Differential Pressure (Forward)	Maximum Operating Temperature
5.0bar @ 25 °C	80°C
2.0bar @ 80 °C	

# 3.5 Steam Sterilization(Thermal Stability)

#### 3.5.1 Summary of Methods

The purpose of these tests was to determine the effects of repeated exposure to in-line steam or autoclave cycles on filter integrity using standard PES filters from



production. The filters were flushed with DI water @2.0bar for 15~20mins. Then passed forward flow in base of 2.75bar air test pressure.

During this autoclave study, filters were steamed using high initial differential pressures (1.0bar (14.5 psi)) at 125°C (257°F). The tests were performed in 30 minutes cycles in the forward (out to in) direction.

During the on-line steam sterilization, These filter cartridges were installed in stainless steel housing and steamed in place in the forward(out to in) direction using saturated steam at constant pressure and flow while ensuring effective condensate drainage. After each steam-in-place cycle the filters were cooled by passing dry compressed air through them.

Integrity tests maintained integrity after Sterilized in place and Autoclave to determine the ability of the filter to provide a sterile filtration.

Serial No.	OCycles	10cycles	<b>30cycles</b>	50cyecles	100cycles	150cycles
311170311007	12.5	14.2	12.6	10.5	15.1	10.9
311170311008	12.3	15.1	13.5	16.8	14.7	12.8
311170311012	16.7	17.2	16.8	14.9	19.8	19.3
311100811005	18.5	18.1	16.9	14.8	15.3	17.9
311100811010	10.3	14.2	12.5	11.6	14.5	18.8
311100811009	17.9	17.5	14.9	11.4	14.1	13.2
311100811017	13.4	16.2	15.2	12.2	16.1	18.8
311050611011	12.7	12.5	18.9	13.5	16.7	19.9
311050611009	14.2	14.1	17.8	14.8	14.1	13.1
311050611015	16.9	15.2	16.8	13.5	12.8	19.8

### 3.5.2 Test Results

Forward Flow (mL/min) after the following Number of 30 minutes Steam Cycles.

The Integrity test value standard is forward flow  $\leq 25$  mL/min@2.75bar,test temperature  $20\pm5$  °C.

Forward Flow (mL/min) after the following number of 30 minutes on-line steam cycles

-	-					
Serial No.	0Cycles	10cycles	20cycles	30cyecles	40cycles	50cyecles
401190611020	15.8	16.3	16.5	16.2	16.8	16.1
401190611021	16.6	16.7	16.5	16.9	16.8	16.5
311170311019	14.2	14.7	14.1	14.9	14.5	14.8
311170311021	17.1	17.0	17.5	17.6	17.8	17.7
311050611007	18.2	17.9	18.3	18.6	18.5	18.4

The Integrity test value standard is forward flow  $\leq 25$  mL/min@2.75bar,test temperature  $20\pm5$  °C.

# **3.5.3** Conclusions

PES 0.2µ m filters have been demonstrated to be capable of withstanding multiple in-line steam/autoclave sterilization cycles.

The data presented in this section support the following product claims for in-line steaming/ autoclaving PES 0.2µ m filter cartridges:



Sterilized in Place				Autoclave		
Temp.	Time	ΔP	Cycles	Temp.	Time	Cycles
135℃	30min	30kPa	50	125℃	30min	150

#### **3.6 Cleanness**

3.6.1Gravimetric Extractable

#### 3.6.1.1Summary of Methods

Typical PES 0.2µm filter cartridges from production were used for the tests.

#### Preparation of Filter Samples

Extractables tests were performed on typical production filter cartridges (10inch, 0.6m<sup>2</sup>), which had been autoclaved in order to maximize the quantity of any extractable material present. The filters were wrapped in aluminium foil and autoclaved for half hour at 121°C, using a slow exhaust cycle. Visible droplets of water remaining on the filter elements were allowed to evaporate at room temperature before the extraction was performed.

#### **Extraction Procedure**

Dynamic extraction tests were performed. The test filters were immersed in 1800 ml of extraction fluid in a clean measuring cylinder for 24 hours. For four hours the filter was gently moved up and down. This movement created flow through the filter membrane as a result of the pressure head that was created each time the element was partially lifted out of the liquid.

#### Analysis of Material Extracted

After the extraction,1500mL of the extraction liquid was evaporated to dryness and the non-volatile extractable were determined gravimetrically.

Extraction Fluid	Filter serial number	Gravimetric Extractable (milligrams per Filter)	Average(milligrams)	
	311170311011	9.6	9.7	
DI Water	311170311016	10.0		
	311100811019	9.4		

#### 3.6.1.2 Test Results

#### 3.6.1.3 Conclusions

The extractable determined of PES filter cartridge 0.2µ m were depended by different solvent. The extractable levels under different solvents, different solubility, different temperature and different contact time are not consistent, so it is recommended to test under actual process conditions.

#### 3.6.2 Fiber Releasing

#### 3.6.2.1 Summary of Methods

Typical PES 0.2µm filter Cartridge from production were used for the tests.



#### 3.6.2.2 Test Results

PES 0.2µm Filter – Fiber Shedding Results					
Filter serial number	ilter serial number Number of Fibers in filtrate Forward Flow(mL/min/10"@				
		2.75bar ,20℃)			
311170311013	0	15.8			
311170311002	0	14.9			
311050611003	0	18.5			

The Integrity test value standard is forward flow  $\leq 25$  mL/min@2.75bar,test temperature  $20\pm5$  °C .

#### 3.6.2.3 Conclusions

The PES filter cartridge 0.2µ m from production don't have Fiber releasing and meet the request of FDA 21 CFR 210.3(b)(6).

### **3.7 Biological Safety**

#### 3.7.1 Biological Tests

#### 3.7.1.1 Summary of Methods

These filters are non-toxic per USP Class VI Biological Tests for Plastics.

Systemic Injection Test, Intracutaneous Test as well as Implantation Test were performed to determine the toxicity of this filters. This testing was performed by an independent laboratory.

#### 3.7.1.2 Conclusions

The materials used in PES 0.2µ m filter cartridges from production meet the requirements of Biological Reactivity Tests(in vivo), listed in the current revision of the United States Pharmacopeia (USP) chapter <88>for Class VI –121 °C Plastics.The tests include the Systemic Injection test, the Intracutaneous test and the Implantation test.



# 3.7.2Bacterial Endotoxin: LAL Test

# 3.7.2.1Summary of Methods

The test filter was flushed with each of endotoxin-free normal saline .The filtration amount of per filter area is not more than 1mL/cm<sup>2</sup>. Ensure normal saline flow through the entire filter. The aqueous extract was tested with an LAL reagent and all tubes were incubated at 37± 1°C for 60± 2min.

# 3.7.2.2 Test Results

Extracts from filters contain <0.25EU/mL endotoxin units per milliliter per the USP Bacterial Endotoxins Test. The results are shown in the following table.

PES 0.2µm filterBacterial Endotoxin: LAL Test per USP(+Clotted;-Not Clotted)						
Filter series number	Positive Control	Negative Control	Positive control of sơ <b>test</b> on	Test solution	Test results (0.25EU/mL)	
311100811011			+ +		<0.25	
311100811006			+ +		<0.25	
311050611002	+ +		+ +		<0.25	
311050611005			+ +		<0.25	
311170311022			+ +		<0.25	
311170311023			+ +		<0.25	

# 3.7.2.3 Conclusions

The PES  $0.2\mu$  m filter cartridges from production met the specifications for USP Bacterial Endotoxins Test.

# **3.8 Chemical Compatibility**

The chemical compatibility of PES 0.2µ m filters is shown in the chart below. Recommendations are based upon static soak for 72 hours at 25℃ and 1.0 atmosphere (14.5psi,1.01 bar absolute) pressure. Dynamic (operating) conditions at moderate temperatures (± 10% fluctuation) will not change the recommendations, but high liquid temperature may do so insome cases.

NOTE: This data is intended to provide expected results when filtration device are exposed to chemicals under static conditions for 48hours at 25°C, unless otherwise noted, membrane integrity was tested by bubble point.

This chart is intended only as a guide. User should verify chemical compatibility with a specific filter under actual use condition, such as various temperatures, pressure, and concentration.



R = Resistant.

L = Limited resistance

N = Not resistant

- = No data

Chemicals	PES Membrane filter	PP Plastic Parts	Silicone O- ring	EPDM 0- ring	Viton O- ring
Acetic Acid, glacial	N	R	L	L	N
Acetic Acid, 25%	R	R	R	L	L
Acetic Acid, 10%	R	R	L	L	L
Hydrochloric acid, conc. 35%	R	R	N	N	R
Hydrochloric acid, 20%	R	R	N	N	R
Hydrochloric acid, 3.3%	R	R	-	N	R
Nitric Acid, conc.67%		R	N	-	R
Nitric Acid, 25%	L	R	L	L	R
Sulfuric Acid, conc.96%	N	N	N	_	R
Sulfuric Acid, 16%	R	R	N	_	R
Ammonium Hvdroxide 3N,5.7%	R	R	R	-	R
Ammonium Hvdroxide 6N,11.4%	R	R	R	-	R
Potassium Hydroxide,15%	R	R	N	R	R
Sodium Hydroxide3N,11%	R	R	R	R	R
Sodium Hydroxide,22%	R	R	R	R	R
Amyl Alcohol	R	R	N	R	R
Benzyl Alcohol	R	R	L	-	R
Butanol	R	R	L	-	R
Isopropanol	R	R	R	_	R
Methanol	R	R	R	R	Ν
Ethylene glycol	L	R	R	-	R
Glycerol	L	R	R	R	R
Propylene glycol	L	R	R	_	R
Ethyl ether	R	R	N	Ν	Ν
Tetrahydrofuran	N	R	N	N	N
Tetrahydrofuran,50% v-v	N	R	-	N	N
Acetone	R	R	R	R	N
Cyclohexanone	-	R	L	L	Ν



Methyl Ethyl Ketone (MEK)	R	R	Ν	R	Ν
Methyl Isobutyl Ketone (MIBK)	Ν	R	Ν	R	Ν
Amyl acetate	L	R	Ν	R	Ν
Butyl Acetate	R	R	R	-	Ν
Cellusolve Acetate	R	R	R	-	Ν
Ethyl Acetate	L	R	L	Ν	Ν
lsopropylacetate	L	R	L	R	Ν
Methylacetate	R	R	Ν	R	Ν
Carbon Tetrachloride	L	R	Ν	Ν	R
Chloroform	L	R	Ν	Ν	R
Ethylene dichloride	Ν	R	Ν	-	R
Methylene Chloride	L	R	Ν	Ν	L
Tetrachloroethylene	-	R	Ν	-	R
Trichloroethane	Ν	R	Ν	Ν	-
Benzene	L	Ν	Ν	Ν	R
Toluene	L	Ν	Ν	Ν	R
Xylene	L	Ν	Ν	Ν	R
Cottonseed	-	R	R	-	R
Peanut	R	R	R	-	R
Formaldehyde 37%	R	R	L	R	R
Formaldehyde 4%	R	R	R	R	R
Hexane	L	R	Ν	-	R
Acetonitrile	Ν	R	N	R	R
Dimethyl Formamide(DMF)	Ν	R	R	Ν	L
Dimethylsulfoxide(DMSO)	Ν	R	Ν	Ν	Ν
Kerosene	L	-	Ν	Ν	R
Pyridine	Ν	L	Ν	Ν	Ν
Petroleum spirits	R	R	N	Ν	-
Hydrogen Peroxide	L	R	R	R	_
Ozone	Ν	R	Ν	L	-
Phenol	-	R	_	_	-

-----END-----